

Honmoku plant : Air Quality (Air Pollution Control Law and ordinances)

Substance	Facilities	Legal Limits	Unit	FY2014 Measured Value (Max)	Remarks
Soot and dust	Boiler	0.01	g/m ³ N	<0.005	
Nitrogen oxides (NO _x)	Boiler	45	ppm	29	