

Nissan Motor Kyushu Co.,Ltd. : Air Quality (Air Pollution Control Law and ordinances)

Substance	Facilities	Legal Limits	Unit	FY2014 Measured Value (Max)	Remarks
Sulfur oxide (SOx)	Boiler	2.9	Nm ³ /h	0	
	Total volume	2	Nm ³ /h	0	
Soot and dust	Boiler	0.1	g/m ³	0.0000038	
	Paint oven	0.2	g/m ³	0.0000079	
	Gas turbine	0.05	g/m ³	—	
	Total volume	8	kg/Nm ³	0.00	
Nitrogen oxides (NOx)	Boiler	230	ppm	96	
	Paint oven	230	ppm	93	
	Gas turbine	70	ppm	—	
	Total volume	33	Nm ³ /h	8.2	