

Nissan Technical Center : Air Quality (Air Pollution Control Law and ordinances)

Substance	Facilities	Legal Limits	Unit	FY2014 Measured Value (Max)	Remarks
Soot and dust	Boilers (lamp oil)	0.3	g/m <sup>3</sup> N	<0.003	
	Boilers (gas)	0.1	g/m <sup>3</sup> N	<0.004	
Nitrogen oxides (NO <sub>x</sub> )	Boilers (lamp oil)	150	ppm	120	
	Boilers (gas)	80	ppm	60	
	Boilers (gas)	150	ppm	40	
	Boilers (gas)	60	ppm	48	